

## 2015 ANNUAL DRINKING WATER QUALITY REPORT

PWSID #: 1150185 NAME: Valley Springs Water Company

*Este informe contiene información muy importante sobre su agua de beber. Tradúzcalo ó hable con alguien que lo entienda bien.* (This report contains very important information about your drinking water. Translate it, or speak with someone who understands it.)

### WATER SYSTEM INFORMATION:

This report shows our water quality and what it means. If you have any questions about this report or concerning your water utility, please contact Robert H. Glisson at 610-384-5751. We want you to be informed about your water supply. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the 1<sup>st</sup> and 3<sup>rd</sup> Tuesday of each month.

### SOURCE(S) OF WATER:

Our water sources are 2 permanent ground water wells, 1 reserve ground water well and purchased surface water from PA American Coatesville (PWSDI 1150106).

**Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).**

### MONITORING YOUR WATER:

We routinely monitor for contaminants in your drinking water according to federal and state laws. The following tables show the results of our monitoring for the period of January 1 to December 31, 2015. The State allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data is from prior years in accordance with the Safe Drinking Water Act. The date has been noted on the sampling results table.

### DEFINITIONS AND ABBREVIATIONS:

**Action Level (AL)** - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Maximum Contaminant Level (MCL)** - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL)** - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)** - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Treatment Technique (TT)** – A required process intended to reduce the level of a contaminant in drinking water.

**Mrem/year** = millirems per year (a measure of radiation absorbed by the body)    **pCi/L** = picocuries per liter (a measure of radioactivity)

**ppb** = parts per billion, or micrograms per liter (µg/L)

**ppm** = parts per million, or milligrams per liter (mg/L)

**ppq** = parts per quadrillion, or picograms per liter

**ppt** = parts per trillion, or nanograms per liter

**DETECTED SAMPLE RESULTS:**

Chemical Contaminant	MCL in CCR units	MCLG	Highest Level Detected	Range of Detections	Units	Sample Date	Violation Y/N	Sources of Contamination
Barium (ppm)	2	2	0.256	0.256	ppm	12/15	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Cadmium (ppb)	5	5	3.4	3.4	ppb	12/15	N	Corrosion of galvanized pipes; Erosion of natural deposits; Discharge from metal refineries; Runoff from waste batteries and paints
Chromium (ppb)	100	100	2	2	ppb	12/15	N	Discharge from steel and pulp mills; Erosion of natural deposits
Fluoride (ppm) (1)	2	2	0.61	0.61	ppm	9/15	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Nitrate	10	10	2.37	2.37	ppm	12/15	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Nitrate (ppm) (1)	10	10	2.84	2.84	ppm	4/15	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
2,4-D (ppb) (1)	70	70	0.2	0 – 0.2	ppb	Quarterly in 2013	N	Runoff from herbicide used on row crops
Simazine (ppb) (1)	4	4	0.25	0 – 0.25	ppb	Quarterly in 2013	N	Runoff from herbicide used on row crops
Atrazine (ppb) (1)	3	3	0.6	0 - 0.6	ppb	Quarterly in 2013	N	Runoff from herbicide used on row crops
Toluene (ppm)	1	1	0.0029	0.0029	ppm	7/12	N	Discharge from petroleum factories
Alpha emitters (pCi/l)	15	0	3.33	3.33	pCi/l	12/15	N	Erosion of natural deposits

Combined radium (pCi/l)	5 pCi/l	0	1.68	1.68	pCi/l	4/12	N	Erosion of natural deposits
TTHMs [Total trihalomethanes] (ppb)	80	N/A	48.8	4.7-48.8	ppb	Quarterly in 2015	N	By-product of drinking water chlorination
Haloacetic Acids (HAA) (ppb)	60	N/A	13.9	1.02-13.9	ppb	Quarterly in 2015	N	By-product of drinking water disinfection
Chlorine (ppm)	MRDL = 4	MRDLG = 4	1.34	0.7 – 1.34	ppm	Monthly	N	Water additive used to control microbes
Turbidity (NTU) (1)	TT	N/A	100%	100%	TT	Daily	N	Soil run off
Total organic carbon (ppm) (1)	TT	N/A	56.4%	38.2 – 56.4%	TT	RAA	N	Naturally present in the environment

(1) These results are from the water purchased from PA American (PWSID 1150106). RAA = Running Annual Average

Entry Point Disinfectant Residual							
Contaminant	Minimum Disinfectant Residual	Lowest Level Detected	Range of Detections	Units	Sample Date	Violation Y/N	Sources of Contamination
Chlorine	0.40	0.0	0.00 – 3.16	ppm	Daily	Y	Water additive used to control microbes.

Contaminant	Action Level (AL)	MCLG	90 <sup>th</sup> Percentile Value	Units	# of Sites Above AL of Total Sites	Violation of TT Y/N	Sources of Contamination
Lead	15	0	0	ppb	0	N	Corrosion of household plumbing.
Copper	1.3	1.3	0.122	ppm	0	N	Corrosion of household Plumbing.

Microbial						
Contaminants	MCL	MCLG	Highest # or % of Positive Samples	Violation Y/N	Sources of Contamination	
Total Coliform Bacteria	More than 1 positive monthly sample	0	0	N	Naturally present in the environment.	
Fecal Coliform Bacteria or <i>E. coli</i>	0	0	0	N	Human and animal fecal waste.	

## **OTHER VIOLATIONS:**

On January 1, 2015 we had an Entry Point Chlorine Residual 0.0 ppm. reading which rebounded later in the day to a normal level. Subsequently a Public Notification Form was mailed out to affected residences detailing the issue and the appropriate resolution of it.

## **EDUCATIONAL INFORMATION:**

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater run-off, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA and DEP prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA and DEP regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

### **Information about Lead**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Valley Township is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.